


POWRMATIC THERMAL ECONOMIZER SYSTEM

Temperature Readings - Cooling Only

Baltimore, MD



The drawing below indicates the temperature readings obtained in Baltimore, MD at an Athletic Center on Tuesday May 27, 2008. The outside temperature was 100.7°F with a unit thermostat setting of 72°F. The building is 17,850 Sq. Ft.



All temperatures were taken at 3.5' above floor
 Unit model - TE-21C
 40 Tons DX Cooling
 16,000 CFM 3 Hp motors
 Weatherproof,
 Vertical unit,
 One inlet, One outlet
 No ductwork

