


POWRMATIC THERMAL ECONOMIZER SYSTEM

Temperature Readings - Cooling Only

Atlanta, GA

The drawing below indicates the temperature readings obtained at a storage facility in Atlanta, GA on July 23, 2009. The outside temperature was 96°F with a unit thermostat setting of 72°F. The building is 8,000 Sq. Ft. - R11 walls R11 roof insulation. Ceiling height 14' - 18'.

Decibel Readings
 65 Db @10'
 55 Db @100'



All temperatures were taken at 6' above floor
 Unit model - TE-11EC
 20 Tons DX Cooling
 8,000 CFM
 One 5 Hp motor



MAIN OFFICE & FACTORY: P.O. BOX 439

FINKSBURG, MD 21048

PHONE: 410-833-9100

FAX 410-833-7971

TOLL FREE PHONE: 1-800-966-9100

TOLL FREE PHONE: 1-800-966-7971